

Near-Zero NOx Gas Turbine Combustion

Vivek Khanna
Solar Turbines Incorporated
San Diego, California

2nd Distributed Energy Peer Review December 2-4, 2003
Washington D.C.






- Program structure
- Project goals
- Program milestones and schedule
- Technical results and current activities
- Key technical hurdles and plans to overcome
- Project risk
- Other low NOx technology efforts
- Impact on DER



Program Structure





The Development Team

- Program Sponsor
 - U.S. Department of Energy (DOE)
 Office of Distributed Energy, Washington, DC
 - Debbie Haught, Merrill Smith
- DOE Project Management
 - DOE Chicago Operations Office, Argonne, IL
 - Dale Dietzel, Steve Waslo
 - DOE Golden Field Office, Golden, CO
 - Paul Bakke



Program Goals

- Assess and advance an ultra-low NOx R/L combustion system for GTs
 - Seeking a cost-effective alternative to SCR
 - Lower electricity cost
 - No ammonia storage/slip issues
 - Easier citing of GTs





- < 2.5 ppm NOx, < 10 ppm CO, UHC</p>
 - Natural gas
- > 8000-hour durability
- Minimum change to current engine
- Field replaceable



Technical Milestones

- "Proof-of-concept" rig tests
 - Single PCI R/L module
- Demonstrate operability in an "engine environment"
 - Saturn engine test (1 MW)
- Develop a Gen II module design
 - Focus on Taurus 70 (7.5 MW) application
 - Rig test a single T70 module




Long Term Milestones – Beyond Contract Effort

- Full system rig test (12 modules)
- In-house engine test
- Long-term field test
 - Document module durability




Program Schedule





Single Burner Module Configuration



Solar Turbines


Rich/Lean Catalytic Combustion

A Caterpillar Company





Single Injector Tests – T70 Operating Conditions



- Well-mixed, lean stable combustion achieved.
- NOx <3ppm @ 16 atmp for flame temp <2875° F.
- CO < 10 ppm for flame temp > 2660° F.
- Pressure drop < 5%
 - Capable of high firing temperature operation.
 - Dynamic pressure oscillations << 1/4 %
 - Extremely quiet operation achieved, over wide operating range.




Saturn Engine Test

- Short term demonstration in an "engine environment" (1 MW)
 - "External can" combustion system
 - Four module "cluster"
 - Assess transient operability



A Caterpillar Company

Saturn Test Facility



Exhaust (Muffler)

Turbine

Solar Turbines


A Caterpillar Company

Saturn Module Construction






Saturn Combustor Assembly






A Caterpillar Company

Saturn Engine Operation





Saturn Engine Test Results



- NOx <3ppm and CO < 10 ppm achieved between 82% NGP and 89.7% NGP
- Maximum speed limited by limits on scroll temperature
- System response to load changes and engine control very similar to SoLoNOx systems



Current Technical Activity

- Gen II module in design
 - Incorporates a pilot burner
 - Improved flame stabilizer
 - More robust tube bundle design
- Combustor casing and liner mods being defined



Technical Hurdles

- Catalyst durability
- Catalytic element retention
- Catalytic reactor resonance
- Pilot performance
- CO emissions vs liner volume



Plans to Overcome Technical Hurdles

- Complete Gen II design
- Rig tests of a single Gen II module
 - Demonstrate pilot burner performance
- Integrate activities with PCI SBIR
 - Demonstrate catalyst durability
 - Multi-burner rig and engine tests





- All milestones except the last completed successfully
- Minimal technical risk involved in the successful completion of the program
- Shortfall or elimination of future funding can curtail the technical effort



A Caterpillar Company

Other Low NOx Technology Efforts






- Surface Combustion (ALZETA)
- Lean Catalytic Combustion (CESI)
- Low Swirl Injector (LBNL/DOE)
- Catalytic Pilot for DLN (PCI)



A Caterpillar Company

Alzeta Surface Burners





Solar Turbines

CESI Lean Catalytic Combustion


A Caterpillar Company



Solar Turbines

Taurus 70 Lean Catalytic Combustor Concept

A Caterpillar Company





PCI R/L Catalytic Pilot

Uses PCI's Catalytic Technology in DLN Pilot







LBNL Low Swirl Injector Development



SoLoNOx injector converted to an LSI





Impact on DER

- Program goals directly support DER's vision
 - Cleaner, smaller and more efficient units of power generation
 - Opportunities for greater local control of electricity delivery and consumption
 - Enable more efficient utilization of waste heat in combined heat and power (CHP) applications
 - Boosting efficiency and lowering emissions